

IS / ISO 9001



ACC Limited

Damodhar Cement Works

Test Result For

Portland Slag Cement (IS: 455 – 1989)

Despatches made during Week no. – 3 / 2009

Certificate no.- 3 Ref. No. - DM/QC/TC/ 3

	Chemical composition	Result	Requirements as per IS:455-1989
1	% Magnesia	4.2	Not more than 10.0%
	% Insoluble Residue	1.2	Not more than 4.0%
	% Sulfur calculated as SO ₃	2.63	Not more than 3.0%
	% Sulfide Sulfur (S)	0.29	Not more than 1.5%
	% Loss on Ignition	1.6	Not more than 5.0%
	% Total chloride (Cl ⁻)	0.02	Not more than 0.1%
2	Fineness(Blaine)		
	Specific Surface (M ² /Kg)	318	Not less than 225
3	Compressive Strength (MPa)		
	3 Days	22.8	Not less than 16
	7 Days	29.5	Not less than 22
	28 Days Week No.- 52	48.2	Not less than 33
4	Setting Time (Minutes)		
	Initial	140	Not less than 30
	Final	225	Not more than 600
5	Soundness		
	Le-Chatelier Expansion (mm)	1	Not more than 10
	Auto-Clave expansion (%)	0.07	Not more than 0.8
6	Normal Consistency (%)	28.5	
	Temp. During Testing (°C)	27	27 ± 2

Officer QA

Chief Manager Production

